

Professional Engineer's Certification:

I certify that I have reviewed the design/construction records related to the CCR unit noted below or discussed the construction of such unit with personnel to attest that it was not constructed with a liner meeting the requirements of section 40 CFR 257.71 (a).

AEP Generation Resources
Gavin Plant
Bottom Ash Pond



Gary F. Zych, P.E.
American Electric Power Service Corporation
Engineering Services

